



ControlNet PLC-5 Programmable Controllers

Series F, Revision D
Series E, Revision J
Series D, Revision K
Series C, Revision T

Introduction

Use these release notes with the following series and releases of ControlNet PLC-5[®] processors:

Series/Revision	Catalog Numbers
Series F, Revision D	1785-L20C15, -L40C15, -L46C15, -L80C15
Series E, Revision J	1785-L20C15, -L40C15, -L46C15, -L80C15
Series D, Revision K	1785-L20C15, -L40C15, -L60C15, -L80C15
Series C, Revision T	1785-L20C15, -L40C15

What This Document Describes

For information about:	See page:
Firmware Compatibility and Maintenance Requirements	2
Software Requirements	2
Downloading or Ordering a User Manual	2
ControlNet PLC-5 Processor Enhancement	3
Updated Timeout Switchover Formula for Hot Backup Applications	3
Known Anomaly	4

Before You Begin

IMPORTANT ControlNet PLC-5 programmable controllers in a hot backup system must have compatible firmware revisions. Refer to the table in the following section to determine compatibility.

Firmware Compatibility and Maintenance Requirements



For General Applications

If your version of RSNetworx does not recognize a newer ControlNet PLC-5 processor, you may need to update your RSNetworx software or the Electronic Data Sheet for the processor. To update your EDS file, use the Hot Backup CD that was shipped with your processor. If you don't have the CD, contact Rockwell Automation Technical Support at 440-646-5800 to update your EDS files.

For Backup Applications

This Series, Revision of Firmware:	Is only compatible with:
Series F/Revision D	Series F/Revision D
Series F/Revisions C, C.1, C.2 and C.3	Series F/Revisions C, C.1, C.2 and C.3
Series F/Revisions B and B.1	Series F/Revisions B and B.1
Series F/Revisions A, A.1, A.2 and A.3	Series F/Revisions A, A.1, A.2 and A.3

Be sure that all **spare** ControlNet PLC-5 hot backup processors contain compatible firmware.

Software Requirements

Use the following table to understand specific features that are only available with specific versions and releases of software.

If you want this feature:	You need both of these versions of software:	
	RSLogix5	RSNetworx
Standard functionality	2.2 or later	1.8 or later
Hot Backup (1771 and Flex I/O)	3.21 or later	1.8 or later
Multicast Outputs	3.21 or later	3.0 or later
SLC I/O (also with Hot Backup)	5.0 or later	3.0 or later

Downloading or Ordering a User Manual

You can download an electronic version or order a printed copy of the ControlNet PLC-5 Programmable Controllers User Manual, publication 1785-UM022B-EN-P:

- download a free electronic version from the internet at: www.ab.com/manuals or www.theautomationbookstore.com
- order a printed manual by:
 - contacting your local distributor or Rockwell Automation representative
 - visiting www.theautomationbookstore.com to place your order
 - calling 1.800.963.9548 (USA/Canada) or 001.330.725.1574 (outside USA/Canada)

ControlNet PLC-5 Enhancement

Series F, Revision C.3

The following table describes the enhancement in the previous release of ControlNet PLC-5 processors.

Enhancement:	Description:
Enhanced diagnostics	Additional diagnostic information is saved when a fault with memory loss occurs.

Updated Timeout Switchover Formula for Hot Backup Applications

Series F, Revision C.3

Timeout Switchover occurs when the secondary processor loses communication with the primary processor for a certain length of time, times out the primary processor, and then performs a switchover. The following events can cause a Timeout Switchover:

- Primary PLC-5 system failure.
- Loss of power to the primary PLC-5 system
- Problems with the ControlNet network which causes loss of the handshake connection with the primary processor.

The following formula determines the length of time the secondary system waits before timing out the primary processor:

$$\text{Primary Timeout} = (3 \times \text{NUT}) \text{ or } 20\text{ms, whichever is greater} + 10\text{ms} + 1\text{ms for every 8 scheduled connections.}$$

For example: If the NUT is 5ms with 20 scheduled connections, the Primary Timeout is $20 + 10 + 2$ or 32ms. If the NUT is 10ms with 80 scheduled connections, the Primary Timeout is $30 + 10 + 10$ or 50ms.

The Primary Timeout is not the only factor in the Timeout Switchover Time. There is also processing which must occur on the secondary system after a Primary Timeout occurs. This processing can take up to 5ms. The formula for the Timeout Switchover Time is:

$$\text{Timeout Switchover Time} = \text{Primary Timeout} + 5\text{ms.}$$

So, if the NUT is 5ms with 20 scheduled connections, the Timeout Switchover Time is equal to 32ms plus 5ms, or 37ms.

Known Anomaly

The following is a known anomaly that has **not** been corrected in any series of PLC-5/80C processors:

Under certain network configurations, the PLC-5/80C processor will only support 127 (out of a possible 128) I/O Map Table Entries. The processor may fault with memory loss when all 128 I/O Map Table Entry connections are established.

Rockwell Automation Support

Rockwell Automation provides technical information on the web to assist you in using our products. At <http://support.rockwellautomation.com>, you can find technical manuals, a knowledge base of FAQs, technical and application notes, sample code and links to software service packs, and a MySupport feature that you can customize to make the best use of these tools.

For an additional level of technical phone support for installation, configuration and troubleshooting, we offer TechConnect Support programs. For more information, contact your local distributor or Rockwell Automation representative, or visit <http://support.rockwellautomation.com>.

Installation Assistance

If you experience a problem with a hardware module within the first 24 hours of installation, please review the information that's contained in this manual. You can also contact a special Customer Support number for initial help in getting your module up and running:

United States	1.440.646.3223 Monday – Friday, 8am – 5pm EST
Outside United States	Please contact your local Rockwell Automation representative for any technical support issues.

New Product Satisfaction Return

Rockwell tests all of our products to ensure that they are fully operational when shipped from the manufacturing facility. However, if your product is not functioning and needs to be returned:

United States	Contact your distributor. You must provide a Customer Support case number (see phone number above to obtain one) to your distributor in order to complete the return process.
Outside United States	Please contact your local Rockwell Automation representative for return procedure.

PLC-5, RSLinx, RSLogix5, and RSNetWorx are trademarks of Rockwell Automation.
ControlNet is a trademark of ControlNet International, Limited.
Ethernet is a registered trademark of DEC, Intel, and Xerox Corporation.

www.rockwellautomation.com

Corporate Headquarters

Rockwell Automation, 777 East Wisconsin Avenue, Suite 1400, Milwaukee, WI, 53202-5302 USA, Tel: (1) 414.212.5200, Fax: (1) 414.212.5201

Headquarters for Allen-Bradley Products, Rockwell Software Products and Global Manufacturing Solutions

Americas: Rockwell Automation, 1201 South Second Street, Milwaukee, WI 53204-2496 USA, Tel: (1) 414.382.2000, Fax: (1) 414.382.4444

Europe: Rockwell Automation SA/NV, Vorstlaan/Boulevard du Souverain 36-BP 3A/B, 1170 Brussels, Belgium, Tel: (32) 2 663 0600, Fax: (32) 2 663 0640

Asia Pacific: Rockwell Automation, 27/F Citicorp Centre, 18 Whitfield Road, Causeway Bay, Hong Kong, Tel: (852) 2887 4788, Fax: (852) 2508 1846

Headquarters for Dodge and Reliance Electric Products

Americas: Rockwell Automation, 6040 Ponders Court, Greenville, SC 29615-4617 USA, Tel: (1) 864.297.4800, Fax: (1) 864.281.2433

Europe: Rockwell Automation, Brühlstraße 22, D-74834 Elztal-Dallau, Germany, Tel: (49) 6261 9410, Fax: (49) 6261 17741

Asia Pacific: Rockwell Automation, 55 Newton Road, #11-01/02 Revenue House, Singapore 307987, Tel: (65) 351 6723, Fax: (65) 355 1733

Publication 1785-RN522F-EN-P - February 2004

Supersedes Publication 1785-RN522E-EN-P - April 2003

PN 957867-29

Copyright © 2004 Rockwell Automation, Inc. All rights reserved. Printed in the U.S.A.