中国国家强制性产品认证证书

证书编号：2024010307707855

认证委托人名称及地址

Rockwell Automation, Inc.
1201 South Second Street, Milwaukee, WI 53204, USA

生产者名称及地址

Rockwell Automation, Inc.
1201 South Second Street, Milwaukee, WI 53204, USA

生产企业名称及地址

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

产品名称和系列、型号、规格

塑料外壳式断路器
1489-M...; 详见附页

产品标准和技术要求

GB/T 14048.2-2020

上述产品符合《强制性产品认证实施规则　低压电器　低压元器件》（CNCA-C03-02:2024）的要求，特发此证。

发证日期：2024 年 10 月 22 日　　**有效期至：**2029 年 07 月 16 日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站（www.cnca.gov.cn）查询。

签发：谢肇煦

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司

中国国家强制性产品认证证书

证书编号：2024010307707855

Ui：440V;

Ue：AC230V(1P)，AC400V(2P，3P);

In：0.5A, 1A, 1.6A, 2A, 3A, 4A, 5A, 6A, 7A, 8A, 10A, 13A, 15A, 16A, 20A, 25A, 30A, 32A, 35A, 40A, 50A, 60A, 63a;

Ics=11.25kA(0.5-40A), 7.5kA(50-63A); Icu=15kA;

选择性类别：A;

过电流脱扣器类型：热磁式;

极数：1P，2P，3P;

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE
中国质量认证中心有限公司
http://www.cqc.com.cn 北京市丰台区南四环西路188号九区5号楼 100070 电话：+86 10 83886666

中国国家强制性产品认证证书

证书编号：2024010307707855

1. 型号的解释(Explanation of Catalog No.)：

1489	–	M	1	C	100
I		II	III	IV	V

I.	Bulletin Number: 1489					
II.	Ultimate Short-circuit Breaking Capacity: M – 15kA					
III.	Number of Pole: 1 – 1 Pole; 2 – 2 Pole; 3 – 3 Pole					
IV.	Instantaneous tripping current: C, D					
V.	Rated Current: 005 – 630 (0.5A – 63A)					
	005 – 0.5A;	010 – 1A;	016 – 1.6A;	020 – 2A;	030 – 3A;	040 – 4A;
	050 – 5A;	060 – 6A;	070 – 7A;	080 – 8A;	100 – 10A;	130 – 13A;
	150 – 15A;	160 – 16A;	200 – 20A;	250 – 25A;	300 – 30A;	320 – 32A;
	350 – 35A;	400 – 40A;	500 – 50A;	600 – 60A;	630 – 63A	

本页为证书附页，应与证书主页同时使用。

中国国家强制性产品认证证书

证书编号：2024010307707855

本页为证书附页，应与证书主页同时使用。

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2024010307707855

NAME AND ADDRESS OF THE APPLICANT

Rockwell Automation, Inc.
1201 South Second Street, Milwaukee, WI 53204, USA

NAME AND ADDRESS OF THE MANUFACTURER

Rockwell Automation, Inc.
1201 South Second Street, Milwaukee, WI 53204, USA

NAME AND LOCATION OF THE FACTORY

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

PRODUCT NAME,MODEL AND SPECIFICATION

Molded Case Circuit Breaker
1489-M…; Refer to appendix

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.2-2020

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Oct.22,2024 **Valid until:** Jul.16,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).

SIGNATURE: 谢肇煦

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010307707855

Ui：440V;
Ue：AC230V(1P)，AC400V(2P，3P);
In：0.5A, 1A, 1.6A, 2A, 3A, 4A, 5A, 6A, 7A, 8A, 10A, 13A, 15A, 16A, 20A, 25A, 30A, 32A, 35A, 40A, 50A, 60A, 63a;
Ics=11.25kA(0.5-40A), 7.5kA(50-63A); Icu=15kA;
Selectivity Category：A；
Over current release type：Thermomagnetic type；
Poles：1P，2P，3P；

This page is attached to the certificate and should be used at the same time as the certificate page.

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010307707855

1. 型号的解释(Explanation of Catalog No.):

1489	–	M	1	C	100
I		II	III	IV	V

I.	Bulletin Number: 1489					
II.	Ultimate Short-circuit Breaking Capacity: M – 15kA					
III.	Number of Pole: 1 – 1 Pole; 2 – 2 Pole; 3 – 3 Pole					
IV.	Instantaneous tripping current: C, D					
V.	Rated Current: 005 – 630 (0.5A – 63A)					
	005 – 0.5A;	010 – 1A;	016 – 1.6A;	020 – 2A;	030 – 3A;	040 – 4A;
	050 – 5A;	060 – 6A;	070 – 7A;	080 – 8A;	100 – 10A;	130 – 13A;
	150 – 15A;	160 – 16A;	200 – 20A;	250 – 25A;	300 – 30A;	320 – 32A;
	350 – 35A;	400 – 40A;	500 – 50A;	600 – 60A;	630 – 63A	

This page is attached to the certificate and should be used at the same time as the certificate page.

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010307707855

This page is attached to the certificate and should be used at the same time as the certificate page.

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

http://www.cqc.com.cn Building 5, Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P. R. China Tel: +86 10 83886666

中国国家强制性产品认证证书

证书编号：2024010307707856

认证委托人名称及地址

Rockwell Automation, Inc.
1201 South Second Street, Milwaukee, WI 53204, USA

生产者名称及地址

Rockwell Automation, Inc.
1201 South Second Street, Milwaukee, WI 53204, USA

生产企业名称及地址

ABB Bulgaria EOOD - Rakovski branch
District Plovdiv, municipality Stryama, village Stryama 4142, Industrial Zone Rakovski, industrial road 1, nr. 14-18.

产品名称和系列、型号、规格

塑料外壳式断路器
1489-M...; 详见附页

产品标准和技术要求

GB/T 14048.2-2020

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》（CNCA-C03-02:2024）的要求，特发此证。

发证日期：2024 年 10 月 22 日 **有效期至：**2029 年 07 月 16 日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站（www.cnca.gov.cn）查询。

签发：谢肇煦

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司

中国国家强制性产品认证证书

证书编号：2024010307707856

Ui：440V;

Ue：AC230V(1P)，AC400V(2P，3P);

In：0.5A, 1A, 1.6A, 2A, 3A, 4A, 5A, 6A, 7A, 8A, 10A, 13A, 15A, 16A, 20A, 25A, 30A, 32A, 35A, 40A, 50A, 60A, 63a;

Ics=11.25kA(0.5-40A), 7.5kA(50-63A); Icu=15kA;

选择性类别：A;

过电流脱扣器类型：热磁式;

极数：1P，2P，3P;

本页为证书附页，应与证书主页同时使用。

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE
中国质量认证中心有限公司
http://www.cqc.com.cn 北京市丰台区南四环西路188号九区5号楼 100070 电话：+86 10 83886666

中国国家强制性产品认证证书

证书编号：2024010307707856

1. 型号的解释(Explanation of Catalog No.)：

1489	–	M	1	C	100
I		II	III	IV	V

I.	Bulletin Number: 1489					
II.	Ultimate Short-circuit Breaking Capacity: M – 15kA					
III.	Number of Pole: 1 – 1 Pole; 2 – 2 Pole; 3 – 3 Pole					
IV.	Instantaneous tripping current: C, D					
V.	Rated Current: 005 – 630 (0.5A – 63A)					
	005 – 0.5A;	010 – 1A;	016 – 1.6A;	020 – 2A;	030 – 3A;	040 – 4A;
	050 – 5A;	060 – 6A;	070 – 7A;	080 – 8A;	100 – 10A;	130 – 13A;
	150 – 15A;	160 – 16A;	200 – 20A;	250 – 25A;	300 – 30A;	320 – 32A;
	350 – 35A;	400 – 40A;	500 – 50A;	600 – 60A;	630 – 63A	

本页为证书附页，应与证书主页同时使用。

中国国家强制性产品认证证书

证书编号：2024010307707856

本页为证书附页，应与证书主页同时使用。

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2024010307707856

NAME AND ADDRESS OF THE APPLICANT

Rockwell Automation, Inc.
1201 South Second Street, Milwaukee, WI 53204, USA

NAME AND ADDRESS OF THE MANUFACTURER

Rockwell Automation, Inc.
1201 South Second Street, Milwaukee, WI 53204, USA

NAME AND LOCATION OF THE FACTORY

ABB Bulgaria EOOD – Rakovski branch
District Plovdiv, municipality Stryama, village Stryama 4142, Industrial Zone Rakovski, industrial road 1, nr. 14-18.

PRODUCT NAME,MODEL AND SPECIFICATION

Molded Case Circuit Breaker
1489-M…; Refer to appendix

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.2-2020

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Oct.22,2024 **Valid until:** Jul.16,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).

SIGNATURE: 谢肇煦

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010307707856

Ui：440V;
Ue：AC230V(1P)，AC400V(2P，3P);
In：0.5A, 1A, 1.6A, 2A, 3A, 4A, 5A, 6A, 7A, 8A, 10A, 13A, 15A, 16A, 20A, 25A, 30A, 32A, 35A, 40A, 50A, 60A, 63a;
Ics=11.25kA(0.5-40A), 7.5kA(50-63A); Icu=15kA;
Selectivity Category：A；
Over current release type：Thermomagnetic type；
Poles：1P，2P，3P；

This page is attached to the certificate and should be used at the same time as the certificate page.

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010307707856

1. 型号的解释(Explanation of Catalog No.):

1489	–	M	1	C	100
I		II	III	IV	V

I.	Bulletin Number: 1489					
II.	Ultimate Short-circuit Breaking Capacity: M – 15kA					
III.	Number of Pole: 1 – 1 Pole; 2 – 2 Pole; 3 – 3 Pole					
IV.	Instantaneous tripping current: C, D					
V.	Rated Current: 005 – 630 (0.5A – 63A)					
	005 – 0.5A;	010 – 1A;	016 – 1.6A;	020 – 2A;	030 – 3A;	040 – 4A;
	050 – 5A;	060 – 6A;	070 – 7A;	080 – 8A;	100 – 10A;	130 – 13A;
	150 – 15A;	160 – 16A;	200 – 20A;	250 – 25A;	300 – 30A;	320 – 32A;
	350 – 35A;	400 – 40A;	500 – 50A;	600 – 60A;	630 – 63A	

This page is attached to the certificate and should be used at the same time as the certificate page.

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010307707856

This page is attached to the certificate and should be used at the same time as the certificate page.

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

http://www.cqc.com.cn Building 5, Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P. R. China Tel: +86 10 83886666