

TEST CERTIFICATE

Issued to: Rockwell Automation
1201 South Second Street
Milwaukee WI, 53204
United States of America

For the product: Low-voltage switchgear and controlgear assembly

Trade name: Allen Bradley

Type/Model: Centerline 2500, 3200 A Air circuit breaker section

Ratings: 3200 A Air circuit breaker MAIN and/or feeder section:
 I_{nA} 2750 A, U_e 480 V, U_i 800 V, U_{imp} 8 kV,
 I_{cw} 80 kA - 1 s, I_{cc} 100 kA at 480 V, 50/60 Hz
For more details see annex

Manufactured by: Rockwell Automation
1201 South Second Street
Milwaukee WI, 53204
United States of America

Subject: Design verification

Requirements: IEC 61439-2:2011
Clauses 10.4, 10.5, 10.9, 10.10, 10.11

Remarks: -

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in report no. 2181593.01-INC, dated 27 July 2016

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 27 July 2016

Number: 2181593.100

DEKRA Certification B.V.

H.R.M. Barends
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed