ATTESTATION OF CONFORMITY

Issued to:	Rockwell Automation Inc. 1201 South Second Street Milwaukee WI 53204 UNITED STATES OF AMERICA
For the product:	Enclosed low-voltage switchgear and controlgear assemblies
Trade name:	Allen-Bradley
Type/Model:	CENTERLINE 2500 with ArcShield
Ratings:	Ue 480 V, Ip arc 65 kA, tarc 300ms, Ipc arc 65 kA, 50 / 60 Hz
Manufactured by:	Rockwell Automation Inc. 1201 South Second Street Milwaukee WI 53204 UNITED STATES OF AMERICA
Subject:	The performance of testing under conditions of arcing due to internal fault.
Requirements:	IEC/TR 61641, Edition 3.0 2014-09 and AS/NZS 3439.1:2002
Remarks:	The product is tested for personnel protection according to IEC/TR 61641 and AS/NZS 3439. Additional assembly protection is tested for outgoing units only; these are tested for conditional short-circuit current under arcing conditions. For testing the most onerous conditions of either IEC/TR 61641 and/or AS/NZS 3439 have been used.

This Attestation of Conformity is granted on account of an examination by DEKRA, the results of which are laid down in Test Report no. 2181593.01-INC, 10 April, 2016.
The examination has been carried out on single samples of multiple configurations representative of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA

Arnhem, 10 April, 2016 Number: 2181593.01A

DEKRA Certification B.V.

F.S. Strikwerda
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands
T +31 88 96 83000 F +31 88 96 83100 www.dekra-certification.com Company registration 09085396