

CERTIFICATE OF COMPLIANCE

Certificate Number 20190301-E334470
Report Reference E334470-20161109
Issue Date 2019-MARCH-01

Issued to: Rockwell Automation Asia Pacific Business Center Pte Ltd
No.2 Corporation Road 06-05/10 Corporation Place
618494 SINGAPORE

**This certificate confirms that
representative samples of**

PROGRAMMABLE CONTROLLERS FOR USE IN
HAZARDOUS LOCATIONS

See Addendum page for Models/Product

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

Standard No. UL 121201-2017 - Nonincendive Electrical
Equipment for Use in Class I and II, Division 2 and Class III,
Divisions 1 and 2 Hazardous (Classified) Locations
Standard No. CAN/CSA C22.2 No. 213-2017 - Non-
incendive Electrical Equipment for Use in Class I, Division 2
Hazardous Locations


Additional Information:

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20190301-E334470
Report Reference E334470-20161109
Issue Date 2019-MARCH-01

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Models/Product:

Programmable Logic Controllers for use in Class I, Division 2, Groups A, B, C and D, Hazardous Locations.

CompactLogix 5000 Adapter - Model 5069-AENTR Series A;
5069 I/O system:
5069-IB8S Series A, 5069-IB8SK Series A – Digital Input modules,
5069-OBV8S Series A, 5069-OBV8SK Series A – Digital Output modules;



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

