TYPE APPROVAL CERTIFICATE
No. **ELE047022CS001**

This is to certify that the product below is found to be in compliance with the applicable requirement of the RINA type approval system.

Description	**Electrical Relay**
Type	**700-HA**
Applicant	**ROCKWELL AUTOMATION** **1201 S 2nd St** **WI 53204 Milwaukee (Wisconsin)** **U.S.A.**
Reference standards	**EN 61810-1: 2015**

Issued in **Genoa** on **March 7, 2022.** *This Certificate is valid until* **March 6, 2027**

RINA Services S.p.A.
Luigi Benedetti

This certificate consists of this page and 1 enclosure

RINA Services S.p.A.
Via Corsica, 12 - 16128 Genova
Tel +39 010 53851
Fax +39 010 5351000

Digitally signed by RINA Services S.p.A. on 16 Mar 2022. No handwritten signature is provided.

TYPE APPROVAL CERTIFICATE
No. **ELE047022CS001**
Enclosure - Page 1 of 1
700-HA

700-HA32/700-HA33(*1)

700-HAB2 / 700-HAB3 / 700-HAX2 / 700-HAX3 (*2)

Rated Value **(*1)**	250 Vac_ 10A ; 250 Vac_ 7A @ cosφ 0,4
Rated Value **(*2)**	250 Vac_ 6A ; 250 Vac_ 4.2A @ cosφ 0,4
Type of operation	Continuous
Ambient Temperature	-40 ÷ +70°C
Insulation Class of coil	F
Electrical operating cycles	100000
Coil control (Vdc) range	6 to 250 Vdc 1,3 W
Coil control (Vac) range	6 to 400 Vac 2.2 VA

Series	No. of contacts	Coil Voltages	Options
700-HA3	2 or 3	A (6 through 400Vac)	XXXXXX
700-HA3	2 or 3	Z (6 through 250Vdc)	XXXXXX

Series	No. of contacts	Coil Voltages	Options
700-HAB	2 or 3	A (6 through 400Vac)	XXXXXX
700-HAB	2 or 3	Z (6 through 250Vdc)	XXXXXX

Series	No. of contacts	Coil Voltages	Options
700-HAX	2 or 3	A (6 through 400Vac)	XXXXXX
700-HAX	2 or 3	Z (6 through 250Vdc)	XXXXXX

Options : Lockable test button + Mechanical Indicator; Lockable test button + LED + mechanical indicator ; etc.

Reference document& Test Report
TA Certificate N.ELE199521CS002

Remarks
Installation and use to be according to the manufacturer instruction

Genoa 07/03/2022

RINA Services S.p.A.
Via Corsica, 12 - 16128 Genova
Tel +39 010 53851
Fax +39 010 5351000

Digitally signed by RINA Services S.p.A. on 16 Mar 2022. No handwritten signature is provided.