EU Declaration of Conformity

Product:	***IEC Contactor Relays, Safety Contactor Relays***

Name and address of the manufacturer: ***Rockwell Automation Inc.*** ***1201 South 2nd Street*** ***Milwaukee, WI 53204*** ***U.S.A.***	*Name and address of the authorised representative:* ***Rockwell Automation NV*** ***Pegasus Park*** ***De Kleetlaan 12A*** ***1831 Diegem*** ***Belgium***

This declaration of conformity is issued under the sole responsibility of the manufacturer.

Object of the declaration:	***Allen-Bradley 700-E, 700S-E, Series*** *(reference the attached list of catalogue numbers)*

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation:

2014/35/EU	*Low Voltage Directive*	*(LVD)*
2014/30/EU	*EMC Directive*	*(EMC)*
2011/65/EU (incorporating 2015/863)	*RoHS Directive*	*(RoHS)*

References to the relevant harmonised standards used or references to the other technical specifications in relation to which conformity is declared:

EN 60947-5-1:2017+AC:2020-05	*Low-voltage switchgear and controlgear – Part 5-1: Control circuit devices and switching elements – Electromechanical control circuit devices*
EN IEC 63000:2018	*Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances*

Signed for and on behalf of the above named manufacturer:

Place and date of issue:	*Aarau, Switzerland*	*27-Jul-2022*
Name, function:	*Daniel Baumann, Manager – Product Compliance Engineering*	
Signature:	i.V. Daniel Baumann	

Catalogue number	*Series* [1]	*Description*
700 – E ∗ ∗ ∗ ∗ 700S – E ∗ ∗ ∗ ∗		*IEC Contactor Relays per Nomenclature* *IEC Safety Contactor Relays per Nomenclature*

1) Products of the series level indicated, as well as succeeding series levels, are certified. If no series letter or number is given, then all series are certified.

NOMENCLATURE:

IEC Contactor Relays and IEC Safety Contactor Relays
Catalogue Number Explanation

700S – E	F	440	KJ	C
1	2	3	4	5

Position	*Catalogue No. Suffix*	*Options/Descriptions*
1		*Base Catalogue Number*
	700 – E	*IEC Contactor Relay*
	700S – E	*IEC Safety Contactor Relay*
2		*Terminal Type*
	F	*Screw terminal*
3		*Contact Configuration*
	220, 310, 400	*Contact configuration of contactor relay*
	440, 530, 620	*Contact configuration of safety contactor relay*
4		*Coil Control Voltage Code*
	KJ	*24…60 VAC / 20…60 VDC*
	KY	*48…130 VAC/VDC*
	KD	*100…250 VAC/VDC*
	KN	*250…500 VAC/VDC*
	EQ	*12…20 VDC, low power consumption*
	EJ	*24…60 VAC / 20…60 VDC, low power consumption*
	QJ	*24 VDC, low power consumption, fast drop-out*
5		*Contacts*
	Blank	*No contact block provided (700 – E)*
	C	*Contact block permanently fixed (700S – E)*