Australian Declaration of Conformity

The undersigned, representing the Manufacturer:	*and the Authorised Supplier within Australia:*
Rockwell Automation Inc.	***Rockwell Automation Australia Ltd.***
1201 South 2nd Street	***L1/248 Burwood Road***
Milwaukee, WI 53204	***Hawthorn, Vic. 3122***
U.S.A.	***Australia***

Herewith declare that the Products:	***IEC Contactor Relays, Safety Contactor Relays***
Product identification:	***Allen-Bradley 700-E, 700S-E Series*** *(reference the attached list of catalogue numbers)*

are in conformity with the following ACMA legislative instruments when installed in accordance with the installation instructions contained in the product documentation:

Radiocommunications Act 1992

- *Radiocommunications Equipment (General) Rules 2021*
- *Radiocommunications (Electromagnetic Compatibility) Standard 2017*
- *Radiocommunications Labelling (Electromagnetic Compatibility) Notice 2017*

and that the standards and/or technical specifications referenced below have been applied:

EN 60947-5-1:2017+AC:2020-05	*Low-voltage switchgear and controlgear – Part 4-1: Contactors and motor-starters – Electromechanical contactors and motor-starters*

Signed for and on behalf of the above named Manufacturer:

Place and date of issue:	*Aarau, Switzerland*	*26-Sep-2023*
Name, function:	*Daniel Baumann, Manager – Product Compliance Engineering*	
Signature:	i.V. Daniel Baumann	

Catalogue number	*Series* [1]	*Description*
700-E**** 700S-E****		*IEC Contactor Relays per Nomenclature* *IEC Safety Contactor Relays per Nomenclature*

1) Products of the series level indicated, as well as succeeding series levels, are certified. If no series number is given, then all series are certified.

MODEL NOMENCLATURE:

IEC Contactor Relays and IEC Safety Contactor Relays
Catalogue Number Explanation

700S-E	F	440	KJ	C
1	2	3	4	5

Position	*Catalogue No. Suffix*	*Options/Descriptions*
1		*Base Catalogue Number*
	700-E	*IEC Contactor Relay*
	700S-E	*IEC Safety Contactor Relay*
2		*Terminal Type*
	F	*Screw terminal*
3		*Contact Configuration*
	220, 310, 400	*Contact configuration of contactor relay*
	440, 530, 620	*Contact configuration of safety contactor relay*
4		*Control Voltage Coil Code (designates coil-voltage and -frequency)*
	KJ	*24…60 VAC / 20…60 VDC*
	KY	*48…130 VAC/VDC*
	KD	*100…250 VAC/VDC*
	KN	*250…500 VAC/VDC*
	EQ	*12…20 VDC, low power consumption*
	EJ	*24…60 VAC / 20…60 VDC, low power consumption*
	QJ	*24 VDC, low power consumption, fast drop-out*
5		*Contacts*
	Blank	*No contact block provided (700-E)*
	C	*Contact block permanently fixed (700S-E)*