UK Declaration of Conformity

Product:	***IEC Contactor Relays, Safety Contactor Relays***
Name and address of the manufacturer: ***Rockwell Automation Inc.*** ***1201 South 2nd Street*** ***Milwaukee, WI 53204*** ***U.S.A.***	*Name and address of the authorised representative:* ***Rockwell Automation Ltd.*** ***Pitfield*** ***Kiln Farm*** ***Milton Keynes*** ***MK11 3DR***
This declaration of conformity is issued under the sole responsibility of the manufacturer.	
Object of the declaration:	***Allen-Bradley 700(S)-E Series*** *(reference the attached list of catalogue numbers)*
The object of the declaration described above is in conformity with the relevant UK Statutory Instruments (and their amendments):	
2016 No. 1101	*Electrical Equipment (Safety) Regulations (LV)*
2016 No. 1091	*Electromagnetic Compatibility Regulations (EMC)*
2012 No. 3032	*Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations (RoHS)*
References to the relevant designated standards used or references to the other technical specifications in relation to which conformity is declared:	
EN 60947-5-1:2017+AC:2020-05	*Low-voltage switchgear and controlgear – Part 5-1: Control circuit devices and switching elements – Electromechanical control circuit devices*
EN IEC 63000:2018	*Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances*
Signed for and on behalf of the above named manufacturer:	
Place and date of issue:	*Milwaukee, WI USA* *30-Jun-2024*
Name, function:	*Daniel L. Nachtigall, Technical Leader – Product Compliance Engineering*
Signature:	

Catalogue number	*Series* [1]	*Description*
700 – E * * * *		*IEC Contactor Relays per Nomenclature*
700S – E * * * *		*IEC Safety Contactor Relays per Nomenclature*

1) Products of the series level indicated, as well as succeeding series levels, are certified. If no series letter or number is given, then all series are certified.

NOMENCLATURE:

IEC Contactor Relays and IEC Safety Contactor Relays
Catalogue Number Explanation

700S – E	**F**	**440**	**KJ**	**C**
1	2	3	4	5

Position	*Catalogue No. Suffix*	*Options/Descriptions*
1		Base Catalogue Number
	700 – E	IEC Contactor Relay
	700S – E	IEC Safety Contactor Relay
2		Terminal Type
	F	Screw terminal
3		Contact Configuration
	220, 310, 400	Contact configuration of contactor relay
	440, 530, 620	Contact configuration of safety contactor relay
4		Coil Control Voltage Code
	KJ	24…60 VAC / 20…60 VDC
	KY	48…130 VAC/VDC
	KD	100…250 VAC/VDC
	KN	250…500 VAC/VDC
	EQ	12…20 VDC, low power consumption
	EJ	24…60 VAC / 20…60 VDC, low power consumption
	QJ	24 VDC, low power consumption, fast drop-out
5		Contacts
	Blank	No contact block provided (700 – E)
	C	Contact block permanently fixed (700S – E)