Certificate of Compliance

Certificate: 2187810 **Master Contract:** 150062

Project: 70034350 **Date Issued:** July 28, 2015

Issued to: **Rockwell Automation BV**

Allen-Bradley
1201 South Second St
Milwaukee, WI 53204
USA
Attention: Ms. Denise L. Denault

The products listed below are eligible to bear the CSA Mark shown

T. Munteanu

Issued by: T. Munteanu, P.Eng.

PRODUCTS

CLASS 3218 02 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices-For Hazardous Locations

Class I, Division 2, Groups A, B, C and D; Refer to Table 1 for temperature code ratings.

PARTS A and B:

Supplementary certification of Bulletins 800H and 800T pilot lights to cover revisions to the pilot light construction details.

Notes:
- Devices are Certified for use in other equipment where the suitability of the combination is subjected to acceptance by CSA or the local inspection authority.
- These devices may be housed in general or special purpose (CSA Encl. 3 or 4) enclosures.

PART C:

Bulletin 800T scaled contact illuminated push to test pilot lights, illuminated push buttons, illuminated and non-illuminated twist to release units and illuminated and non-illuminated push pull units.

PART D:

Bulletin 800H sealed contact illuminated push to test pilot lights, illuminated pushbuttons, illuminated and non-illuminated twist to release units and illuminated and non-illuminated push-pull units.

Certificate:	2187810	**Master Contract:**	150062
Project:	70034350	**Date Issued:**	July 28, 2015

Note: Devices are Certified for use in other equipment where the suitability of the combination is subjected to acceptance by CSA or the local inspection authority.

Notes:

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 14-13-Industrial Control Equipment

CSA Std C22.2 No. 213-M1987-Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations