Certificate of Compliance

Certificate: 2185028 (LR 11924-82) **Master Contract:** 150062

Project: 70034334 **Date Issued:** July 28, 2015

Issued to: **Rockwell Automation BV**

Allen-Bradley
1201 South Second St
Milwaukee, WI 53204
USA
Attention: Ms. Denise L. Denault

The products listed below are eligible to bear the CSA Mark shown

T. Munteanu

Issued by: T. Munteanu, P.Eng.

PRODUCTS

CLASS 3218 02 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices-For Hazardous Locations

Class I, Division 2, Groups A, B, C and D:

• Bulletin 800T Operator Devices: Momentary Contact Pushbuttons, Maintained Contact Pushbuttons, Cylinder Lock Pushbuttons, Selector Pushbuttons, and Selector Switches with sealed contact blocks. Rated 600V ac/dc max, B600, P300. Ambient temperature 40C max., Temperature Code T6. For use in general purpose, Type 3, or Type 4 Enclosures. Alternatively, may be used with the 800T-XAF flameproof contact block which is rated A600/Q600, Ambient temperature 55ºC maximum, Temperature Code T6.

Models as follows:

Momentary Contact Pushbuttons. Catalog Number 800T, may be followed by C, followed by -A, B, D, DJ, DL, or E, followed by blank or number 0 through 9, followed by blank or P, followed by AP, D1P, or D2P, AF, A16F, FF, HF, KF, CF, JF, G1F, 0, followed by Series letter A through T.

Momentary Contact Pushbuttons with Two Color Molded Legend Caps. Catalog Number 800T, may be followed by C, followed by -A, or B, followed by “00” or a 3 digit number 001 through 999, may be followed by any letter, followed by AP, D1P, D2P, AF, A16F, FF, HF, KF, CF, JF, G1F, 0, followed by Series letter A.

Cylinder Lock Pushbuttons. Catalog Number 800T, may be followed by C, followed by –E, followed by 11, 12, 13, 14, 15, 16, 17, 24, 25, 26, or 27, followed by AP, D1P, D2P, AF, A16F, FF, HF, KF, CF, JF, G1F, 0, followed by Series letter A through T.

Certificate:	2185028 (LR 11924-82)	**Master Contract:**	150062
Project:	70034334	**Date Issued:**	July 28, 2015

Selector Pushbuttons. Catalog Number 800T, may be followed by C, followed by –K, followed by A, B, C, D, or E, blank or any number 0 through 9, followed by AP, D1P, D2P, AF, A16F, FF, HF, KF, CF, JF, G1F, 0, followed by Series letter A through T.

Selector Switches. Catalog Number 800T, may be followed by C, followed by – H, J, or N, followed by blank or any letter A through Z, followed by any 1, 2 or 3 digit number, followed by blank or 2 digit number, followed by blank or K + letter + 1 digit number, followed by four letters any combination of A, D, E, G, J, K, L, P, R, S, T, V, W, X, Y, 0, or Z, followed by Series letter A through T.

Maintained Contact Pushbuttons. Catalog Number 800T, may be followed by C, followed by –F, or G, followed by blank, Y, or Z, followed by any letter A through V, followed by blank or P, followed by E, followed by 11, 12, 13, 14, 15, 16, 17, 24, 25, 26, or 27, followed by AP, D1P, or D2P, AF, A16F, FF, HF, KF, CF, JF, G1F, 0, followed by Series letter A through T.

Pushbuttons. Catalog Numbers 800T-NX, followed by a four digit number 0000 through 9999, followed by series letter A, B, C, N, Q, T, or U.

• Bulletin 800H Operator Devices: Momentary Contact Pushbuttons, Maintained Contact Pushbuttons, Selector Switches , Flip Lever Pushbuttons and Open Type Non-Illuminated Push-Pull And Twist-To-Release Units with sealed contact blocks. Rated 600V ac/dc max, B600, P300. Ambient temperature 40C max., Temperature Code T6. For use in general purpose, Type 3, or Type 4 Enclosures. Alternatively, may be used with the 800T-XAF flameproof contact block which is rated A600/Q600, Ambient temperature 55ºC maximum, Temperature Code T6.

Models as follows:

Momentary Contact Pushbuttons. Catalog number 800H, may be followed by C or S, may be followed by A, B, D, or G, may be followed by R, followed by any number 0 through 9, may be followed by J or P, followed by four letters any combination of A, D, E, G, J, K, L, P, R, S, T, V, W, X, Y, 0 or Z, followed by Series letter A through F.

Momentary Contact Pushbuttons with Two Color Legend Caps. Catalog number 800H, may be followed by C or S, may be followed by -A, or B, followed by “00” or a 3 digit number 001 through 999, may be followed by any letter, followed by four letters any combination of A, D, E, G, J, K, L, P, R, S, T, V, W, X, Y, 0 or Z, followed by Series letter A.

Maintained Contact Pushbuttons. Catalog number 800H, may be followed by C or S, followed by -F or C, may be followed by R, may be followed by Y or Z, followed by A, B, E, or J, followed by any number 0 through 9, may be followed by any number 0 through 9, followed by four letters any combination of A, D, E, G, J, K, L, P, R, S, T, V, W, X, Y, 0 or Z, followed by Series letter A through F.

Selector Switches. Catalog number 800H, may be followed by C, followed by -H, J, or N, may be followed by R, may be followed by A, B, C, D, E, or G, followed by 2, 4, 5, 70, or 91, followed by K, followed by any alpha character (A through Z), followed by a numeric character (0 through 9), followed by four letters any combination of A, B, C, D, E, G, J, K, L, P, R, S, T, V, W, X, Y, 0 or Z, followed by Series letter A through F.

Flip Lever Pushbuttons. Catalog Numbers 800H, may be followed by C, followed by WK4 or WK6, may be followed by one or two digits, followed by any combination of letters and/or numbers, followed by Series letter D.

Open Type Non-Illuminated Push-Pull And Twist-To-Release Units. Catalogue Number 800H, may be followed by C, followed by -FRX or FMX, with or without J, followed by T, with or without 1, 2, 3, 4, 6, 7 or 9, followed by additional suffix letters or letters and numbers, followed by Series letter F.

APPLICABLE REQUIREMENTS

CAN/CSA Standard C22.2 No. 0-M91 (Reaffirmed 2006) - General Requirements - Canadian Electrical Code, Part II

CAN/CSA Standard C22.2 No. 94-M94 (Reaffirmed 2006) - Special Purpose Enclosures

CAN/CSA Standard C22.2 No. 14-05 (with updates 1-3, April 2008) - Industrial Control Equipment

CSA Standard C22.2 No. 213-M1987 (Reaffirmed 2008) - Non-incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations